

1		2		3		4		5		6		7		8															
A	系统名称:高质水控制柜														A														
	主母排规格																												
	一次额定电压:400V																												
	二次额定电压:AC220V																												
B	一次方案														B														
C															C														
D	柜号		PD-1												D														
	柜尺寸(W*D*H:mm)		600*1000*2200																										
	柜用途		GGD柜																										
	柜属性		GGD柜																										
	回路属性																												
	回路编号		1		2		3		4		5		6			7		8		9		10							
	回路名称																												
回路原理				工频		变频		变频		工频																			
E	主要元件	塑壳断路器	NM1-125H/3300-125A	1	NM1-63H/3300-40A	1	NM1-63H/3300-40A	1	变频器:ACS510-15kW	1	NM1-63H/3300-40A	1	DZ47-60/3P C50A	1	DZ47-60/3P C40A	1	DZ47-60/2P C25A	1	DZ47-60/2P C20A	1	AC30-10530	1							
		接触器			CJX1-40A	1	CJX1-40A	1	CJX1-40A	1	CJX1-40A	1																	
		热继电器			NR4-63F/25-40A	1					NR4-63F/25-40A	1																	
		电流互感器	LMZJ1-0.5 150/5A Ø50 0.5级 1匝	3																									
		电流表	42L6-A 150/5A	3																									
		电压表	42L6-V 450V	1																									
F	柜备注																						F						
	回路备注		总进线				1#高质水泵								2#高质水泵				备用		备用			备用		备用		柜内插座	
	馈线电缆编号																												
	电缆型号																												
G	控制电缆编号																						G						
	电缆型号																												
H	备注: 1、柜门内侧安装图纸收纳盒。柜门带限位止动器，配置照明及风扇; 2、柜体色标RAL7032;材料采用优质冷轧钢板,厚度1.2mm,表面防静电喷涂; 3、柜体为上进上出线,接线端子均布置在柜上方; 4、高质水回路为变频一拖二,柜门面板配置本地/远程切换、工/变频切换、本地启停按钮、运行指示、故障指示等,并且二次回路配置远程开停泵(开、停两点)、运行信号、故障信号等接点;																						H						
1		2		3		4		5		6		7		8															